

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. Located on map Received:

1) OWNER: Person having well drilled Mr. Harold R. Parker Address 2211 Sinclair Midland, TX 79701 Landowner same Address

2) LOCATION OF WELL: County Llano miles in direction from (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*

Well #17, Llano County map

North

(Use reverse side if necessary)

Give legal location with distances and directions from adjacent sections or survey lines.

Labor League

Block Survey

Abstract No.

(NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well X Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic X Industrial Municipal Irrigation Test Well Other 5) TYPE OF WELL (Check): Rotary X Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 in. Depth drilled 120 ft. Depth of completed well 120 ft. Date drilled 6-9-78 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include topsoil, granite gravel and clay, metamorphic sand, black and white metamorphic, pink metamorphic, black metamorphic with fractures.

9) Casing: Type: Old New X Steel X Plastic Other Cemented from ft. to ft.

Diameter (inches) Setting From (ft.) To (ft.) Gage 6 plus 2 25 .188

10) SCREEN: Type Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole X

8) WATER LEVEL: Static level 12 ft. below land surface Date 6-9-78 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., ft. below land surface.

11) WELL TESTS: Was a pump test made? Yes No X If yes, by whom? Yield: 8-10 gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

12) WATER QUALITY: Was a chemical analysis made? Yes No X Did any strata contain undesirable water? Yes No Type of water? depth of strata

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME Taylor Virdell Water Well Drillers Registration No. 240

ADDRESS 111 E. Grayson St. Llano Texas 78643

(Signed) Virdell Drilling Inc. (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.