

STATE OF TEXAS WATER WELL REPORT

1) OWNER: MILLER, MARC ADDRESS: P.O. BOX 775 CITY: LLANO STATE: TX ZIP: 78643-
 2) LOCATION OF WELL: County: LLANO 1 miles in S direction from HWY. 71 on Co. Rd. 402 (Salem Cemetery Rd.);
 900' East in pasture

LEGAL DESCRIPTION SEE ATTACHED MAP

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC 5) DRILLING METHOD: AIR ROTARY/HAMMER

6) WELL LOG: 92002 DIAMETER OF HOLE 7) BOREHOLE METHOD:
 DIAMETER FROM TO
 10" 0 19.5 OPEN HOLE
 6" 19.5 100 IF GRAVEL... FROM FT. TO FT.
 FROM FT. TO FT.

DATE DRILLED: 01/15/92

GEOLOGICAL DESCRIPTION:		8) CASING, BLANK PIPE, AND WELL SCREEN DATA:				
FROM	TO	DESCRIPTION	DIA	NEW/USED	SCREEN DATA	
0	2	META/SCHIST-BL/GRAY	6"	N	PVC CASING	FROM TO GAGE CASING SCREEN +1.5 19.5 SCH 40
2	15	GRAVEL & CLAY			-----	
15	18	METAMORPHIC - WEATHERED			-----	
18	55	METAMORPHIC - BLACK & RED			-----	
55	100	METAMORPHIC - RED			-----	

9) CEMENTING DATA:
 Cemented from 3 FT. TO 19.5 FT.
 FT. TO FT.
 Method used: GROUT
 Cemented by: VIRDELL DRILLING INC

10) SURFACE COMPLETION:
 PITLESS ADAPTER USED

11) WATER LEVEL:
 STATIC LEVEL : 19 FT. DATE: 01/15/92
 ARTESIAN FLOW: GPM. DATE:

12) PACKERS: TYPE DEPTH
 6" BELL PACKER 19.5

13) TYPE PUMP:
 SUBMERSIBLE
 DEPTH TO PUMP: 90'

14) WELL TEST:
 ESTIMATED
 YIELD: 3 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:
 TYPE OF WATER: GOOD DEPTH OF STRATA: 21,51 NO CHEMICAL ANALYSIS MADE
 NO STRATA OF UNDESIRABLE WATER PENETRATED

COMPANY NAME: VIRDELL DRILLING INC. WATER WELL DRILLER'S LICENSE NO.: 1900-W : FOR TOWN USE ONLY
 ADDRESS: 111 E. GRAYSON ST. CITY: LLANO STATE: TX ZIP CODE: 78643 : WELL NO. _____
 : LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 12 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) Wayne Virdeell (signed) _____
 (LICENSED WATER WELL DRILLER) (REGISTERED DRILLER TRAINEE)

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

1) OWNER: MCHILLAN, JENNIFER ADDRESS: HCR 4, BOX 295 CITY: BURNET STATE: TX ZIP: 78611-

2) ADDRESS OF WELL: County: LLANO GRID # 57-10-6
Street or RFD: 1 MI. S FROM HWY. 71 ON CO. RD. 402; 200' W IN PASTURE
City, State, Zip code: TX

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC
If Public Supply well, were plans submitted to the TNRCC?

DATE DRILLING: STARTED: 04/13/98 COMPLETED: 04/13/98	DIAMETER OF HOLE		7) DRILLING METHOD: AIR ROTARY/HAMMER	8) BOREHOLE COMPLETION:		
	DIAMETER	FROM TO		IF GRAVEL...	FROM	FT. TO FT.
	9	0 29		OPEN HOLE		N [^]
	6	29 120				

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PVC CASING	+3	29	SCH 40

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	2	TOPSOIL
2	5	METAMORPHIC-GRAY GRAVEL CLAY
5	28	METAMORPHIC-BLACK GRAVEL STREAKS
28	35	SOLID METAMORPHIC-BLACK
35	40	METAMORPHIC-RED BLACK STREAKS
40	43	RED GRAVEL
43	70	METAMORPHIC-BLACK WHITE STREAKS
70	81	SOFT METAMORPHIC-RED
81	120	METAMORPHIC-BLACK WHITE STREAKS RED STREAKS

9) CEMENTING DATA:

Cemented from 0 FT. TO 29 FT. No. of Sacks Used 2
FT. TO FT.
Method used: GROUT
Cemented by: KEITH FAIN
Distance to septic field lines: ft.
Method of verification of above distance:

10) SURFACE COMPLETION:

PITLESS ADAPTER USED

11) WATER LEVEL:

STATIC LEVEL : 34 FT. DATE: 04/13/98
ARTESIAN FLOW: GPM, DATE:

12) PACKERS: TYPE DEPTH

13) TYPE PUMP:
SUBMERSIBLE
DEPTH TO PUMP: 100

14) WELL TEST:
JETTED
YIELD: 3 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:
TYPE OF WATER: GOOD DEPTH OF STRATA: 55-60
NO STRATA OF UNDESIRABLE WATER PENETRATED

CHEMICAL ANALYSIS MADE
500 T.D.S.

COMPANY NAME: VIRDELL DRILLING INC. WATER WELL DRILLER'S LICENSE NO.: 900 4071 WPKL
ADDRESS: 111 E. GRAYSON ST. CITY: LLANO STATE: TX ZIP CODE: 78643

FOR TWC USE ONLY
WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) Jorge VirdeLL
(LICENSED WATER WELL DRILLER)

(signed) Keith Fain
(REGISTERED DRILLER TRAINEE)